

## Nordyne Placard on M1 & M3 Furnaces



### **CAUTION:**

### **RETAILER/HOMEOWNER INFORMATION**

HUD Manufactured Home Construction and Safety Standards (3280.714) prohibit the use of noncertified air conditioning or heat pump equipment with this furnace. It is strongly recommended that NORDYNE manufactured housing air conditioning components (Intertherm or Miller brands) be selected to provide a matched system specifically designed to meet these requirements.

The cutting, splicing or modifying of any internal electrical wiring may void product warranties and create a hazardous condition. Failure to comply with these standards could also provide inadequate heating or cooling performance and cause structural damage to a manufactured home.

Please contact your local Intertherm or Miller distributor for help. A directory of NORDYNE factory authorized service is located in the furnace homeowner packet.

Reference: HUD Manufactured Home Construction and Safety Standards 3280.714.

7039130

#### **Control Module Status Indicators - M1M Series**

##### **Red LED**

Steady ON:	Control OK
Steady OFF:	No power.
Rapid flash:	False flame or internal control fault.
One flash:	Limit switch is open.
Two flashes:	Pressure switch is open.
Three flashes:	Pressure switch is closed.